

TS8100-DUAL-V THERMOSTAT INSTRUCTIONS



LCD SYMBOLS

Symbol	Event	Symbol	Event
B	The buttons are locked	AUTO	Automatic mode, executes the programmed schedules
٥	Heating is turned on	Override	Temporary temperature override
	Frost protection activated	Err	The floor sensor is not being read by the thermostat
ថា	Program number	C	Economy temperature
13	Manual mode	*	Comfort temperature



CONFIGURATION MENU

To enter into the setting menu please follow the steps below:

Step 1, Turn the thermostat off by pressing POWER;

Step 2, Press MENU , you will then see menu 01.

Step 3, Use the up and down arrows to adjust menu 01.

Step 4, Press NEXT to move to the next Menu,

Setp 5, Press DONE to accept and store once you have all menu options set.

TURNING ON/OFF THE THERMOSTAT

Press POWER button to turn on/off the thermostat. When thermostat is turned off, the LCD will display OFF. The outputs for all zones will be turned off.

ALTERNATING THE ZONES

In order to alternate between the zones you should press ZONE , the LCD will display ZONE 1 or ZONE 2 at top left corner.

Menu #	Feature	Explanation	Adjustment (press up & down buttons to adjust)
01	Mode/Sensor selection(Zone 1 only)	This thermostat is a combination model which allows you to choose 3 different modes. A mode=Air Sensing Only(Has built in sensor) AF mode=Air & Floor sensing(Floor probe must be installed) F mode=Floor Sensing(Floor probe must be installed)	A, AF, F
02	Maximum Floor Temp (AF mode only) (Zone 1 only)	This is to protect the floor surface. For Wooden floors - When the manufacturer has set a temperature limit.	20 °C~ 40 °C (40 °C by default)
03	5+2 / 7 Day Mode	This allows you to program either 5 days at once, then the 2 days of the weekend separately, or a full 7 days at the same time or 7 days separately	01 = 5+2 day programmable 02 = 7 day programmable

SETTING THE CLOCK + DAY OF THE WEEK

Setting the clock and day of the week

This thermostat is fitted with a real time clock. It is essential that the clock time and day are set accurately if you require your programmed events to start on time. To set follow the steps below:

1 Touch the time display and the time will start flashing. Use the up and down arrows to set the time. By holding the arrow down the time will change faster.

2 Press NEXT to move to the Day setting and use the up and down arrows to get to the correct day.

3 Press DONE to store and exit

Radiant Floor Heating WA Pty Ltd Unit 1 / 18 Profit Pass, Wangara, WA 6065

Telephone: 08 6300 0404 **Email:** sales@floorheatingwa.com.au





SETTING THE PROGRAM SCHEDULES

This thermostat has the ability to program each individual day of the week separately, or program 7 days of the week at once. You can also program weekdays (5 days)to one schedule and then weekends (2 days) to a different schedule. See the Menu information for details on how to set this up.(refer to Menu 10 for zone 1 and menu 02 for zone 2)

Program	Start Time	Setpoint		Explanation
		zone 1	zone 2	Explanation
1	WAKE 07:00	22°C	ON	Set to the time you would like to wake to and the temperature you want during the morning, until you left for the day.
2	LEAVE 09:30	16 °C	ON	Set to the time you leave home and the temperature you wish your home to maintain while you are away at work perhaps.
3	RETURN 16:30	22 °C	ON	Set to the time you return home at end of the day and the temperature you want during evening until bed time.
4	SLEEP 22:30	16°C	ON	Set to the time you sleep and the temperature you want overnight (usually a comfortable and energy saving temperature).

Above are default program schedules, to make changes, follow easy steps as below
--


A	Above are default program schedules, to	o make changes, follow easy steps as below.	
	1 Press SCHEDULE and the day display will star	t flashing. (If your thermostat is set to 5+2 day programmable mode, the programming will skip to step3)	
	2 Use to adjust the day of the week	you want to start programming or to the day you wish to edit an existing event / program. eek, and to cancel press ALLDAYS again.)	
	3 Press NEXT the LCD screen will show P	rogram 1(🔃) and the time will be flashing.	
	4 Use	e you wish the Program 1 event to commence for the selected day/days .	
	5 Press NEXT and the temperature will sta	rt flashing. (ON/OFF status will start flashing if current zone is set to zone 2)	
	6 Use △ and ▽ to set the desired	I temperature(or ON/OFF stauts for zone 2) to be maintained during Program 1.	
	7 Press NEXT and the LCD screen will sho	ow Program 2 with the time display flashing, this signifies that the second daily event is now ready to be programmed.	
		ograms/events, then press DONE to store and exit. E will clear a program entry and thermostat will maintain the temperature setpoint of the last executed program	

Auto / Manual Mode

Press MODE to select Auto/Manual mode. In Manual mode (), the thermostat maintains a constant set temperature manually set by the user.In Auto mode, the thermostat executes the preprogrammed schedules.

Holiday Function

The Holiday function reduces the temperature in your room to the frost protection temperature. The thermostat will maintain this temperature for the duration of the holiday and will then automatically return to the program mode on your return.



until the beginning of the next program.

Lock the Keypad

To lock the keypad, press and hold the top left corner of display for 5 seconds, you will see a lock symbol $\begin{cal}P\end{cal}$. To unlock, repeat the steps above and the lock symbol will disappear.

Reset to Factory Setting

With thermostat turned off, press and hold OFF for 5 seconds until you can see -: - on LCD.

Temporary Temperature Override

Touch the temperature display, and it will start to flash. Use up or down buttons to adjust. Press | DONE | to accept, and you will see "Override" above the temperature display. Thermostat will maintain the new set temperature until the next programmed event(comfort level). To cancel the override setting, press RUN SCHEDULE

Installation and Wiring

Carefully separate the front half of the thermostat from the back plate by placing a small flat head terminal driver into the slots on the bottom face of the thermostat.

Carefully unplug the ribbon connector which is plugged into the front half of the thermostat. Place the thermostat front half somewhere safe. Terminate the thermostat as shown in the diagrams below.

Screw the thermostat back plate on to the flush box.

Re-connect the thermostat ribbon cable and clip the two halves together.

